



REDACTED

State	Ops Ctr	TCC	Job Type	Job Order	Related JO	Job Status	Job Summary	PSID No	JO Address	City	Commit Dt	Originated By	Create Dt	Completion Date	Completed By	Update Dt	Install Code	Function	Ext Shutoff Valve Accessible	Inlet Pressure	Outlet Pressure as Found	Outlet Pressure Units as Found	Outlet Pressure as Left	Outlet Pressure Units as Left	Reg Function Normal	Major Inspection Performed	Major Inspection Scheduled	Facility	Facility Units Found Code	Facility Found Qty	Facility Units Left Code	Facility Left Qty	Facility Function	Execution Comments
MA	LAWRENCE	8400	2613	18632456300		EX	[REDACTED]		S UNION ST	LAW	12-22-2018	WMS4CMA	08-02-2018	09-19-2018	CU471730	09-19-2018	A	000021670	Y	74.8	0	"WC	0	"WC	Y	N	N	0000488286	"WC	14	"WC	14	MONITOR	ANNUAL INSPECTION WITH PHMS ALL NEG COMPLETED 9/15/18 FUNCTION NUMBER - 000021670, ATMOSPHERIC CORROSION (Y/N) = N FACILITY NUMBER - 0000488286, CHANGE IN REGULATOR CAPACITY = N FACILITY NUMBER - 0000695142, CHANGE IN REGULATOR CAPACITY = N
MA	LAWRENCE	8400	2613	18632456300		EX	[REDACTED]		S UNION ST	LAW	12-22-2018	WMS4CMA	08-02-2018	09-19-2018	CU471730	09-19-2018	A	000021670	Y	74.8	0	"WC	0	"WC	Y	N	N	0000695142	"WC	0	"WC	0	CONTROL	ANNUAL INSPECTION WITH PHMS ALL NEG COMPLETED 9/15/18 FUNCTION NUMBER - 000021670, ATMOSPHERIC CORROSION (Y/N) = N FACILITY NUMBER - 0000488286, CHANGE IN REGULATOR CAPACITY = N FACILITY NUMBER - 0000695142, CHANGE IN REGULATOR CAPACITY = N
MA	LAWRENCE	8400	2613	18632457500		EX	[REDACTED]		MASS AV	NAN	12-21-2018	WMS4CMA	08-02-2018	09-19-2018	CU471730	09-19-2018	A	000021715	Y	74.8	0	"WC	0	"WC	Y	N	N	0000488378	"WC	14	"WC	14	MONITOR	ANNUAL INSPECTION WITH PHMS LOCKED UP ALL NEG FUNCTION NUMBER - 000021715, ATMOSPHERIC CORROSION (Y/N) = N FACILITY NUMBER - 0000488378, CHANGE IN REGULATOR CAPACITY = N FACILITY NUMBER - 0000488379, CHANGE IN REGULATOR CAPACITY = N
MA	LAWRENCE	8400	2613	18632457500		EX	[REDACTED]		MASS AV	NAN	12-21-2018	WMS4CMA	08-02-2018	09-19-2018	CU471730	09-19-2018	A	000021715	Y	74.8	0	"WC	0	"WC	Y	N	N	0000488379	"WC	0	"WC	0	CONTROL	ANNUAL INSPECTION WITH PHMS LOCKED UP ALL NEG FUNCTION NUMBER - 000021715, ATMOSPHERIC CORROSION (Y/N) = N FACILITY NUMBER - 0000488378, CHANGE IN REGULATOR CAPACITY = N FACILITY NUMBER - 0000488379, CHANGE IN REGULATOR CAPACITY = N
MA	LAWRENCE	8400	2613	18640262200		EX	[REDACTED]		BROADWAY	LAW	12-31-2018	WMS4CMA	08-31-2018	09-26-2018	CU471730	11-05-2018	A	000021683	N	0	0	PSIG	0	PSIG	N	N	N	0000488313	"WC	0	"WC	0	MONITOR	ABANDONED LAWRENCE INCADENT
MA	LAWRENCE	8400	2613	18640262200		EX	[REDACTED]		BROADWAY	LAW	12-31-2018	WMS4CMA	08-31-2018	09-26-2018	CU471730	11-05-2018	A	000021683	N	0	0	PSIG	0	PSIG	N	N	N	0000488314	PSIG	0	PSIG	0	CONTROL	ABANDONED LAWRENCE INCADENT