

EVERSOURCE ENERGY
Simplified Interconnection Process Summary

Year	Eastern MA		Western MA	
	Applications	Capacity (kW)	Applications	Capacity (kW)
2010	347	1,932	103	423
2011	685	3,950	222	1,124
2012	1,996	11,813	345	1,664
2013	2,156	13,265	413	2,441
2014	4,603	30,199	1,276	7,999
2015	7,234	49,999	2,643	17,690
2016	5,870	44,460	2,588	18,504
2017	3,937	30,770	2,163	15,727
2018	4,121	33,820	2,082	14,069
2019	4,528	38,440	1,804	11,981
2020	4,476	39,764	1,331	7,187

EVERSOURCE ENERGY
Expedited and Standard Interconnection Process Summary

Year	Eastern MA							Western MA						
	Applications	Capacity (kW)	System Modification Cost					Applications	Capacity (kW)	System Modification Cost				
			Cumulative	Minimum	Maximum	Median	Average			Cumulative	Minimum	Maximum	Median	Average
2013	1	100	\$ -	\$ -	\$ -	\$ -	\$ -	36	10,410	\$ 776,663	\$ -	\$ 368,589	\$ -	\$ 21,574
2014	73	26,340	\$ 1,056,543	\$ -	\$ 266,656	\$ -	\$ 14,473	24	26,072	\$ 1,462,718	\$ -	\$ 483,642	\$ 349	\$ 60,947
2015	161	59,572	\$ 3,823,632	\$ -	\$ 422,000	\$ -	\$ 23,749	48	20,041	\$ 2,575,699	\$ -	\$ 579,353	\$ 123	\$ 53,660
2016	172	84,874	\$ 8,373,775	\$ -	\$ 453,061	\$ 1,025	\$ 48,685	67	48,366	\$ 8,929,142	\$ -	\$ 1,619,411	\$ 358	\$ 133,271
2017	87	58,642	\$ 8,967,519	\$ -	\$ 1,758,276	\$ -	\$ 103,075	51	67,231	\$ 11,450,291	\$ -	\$ 1,093,776	\$ 153,859	\$ 224,516
2018	106	97,538	\$ 9,615,869	\$ -	\$ 1,097,751	\$ 1,473	\$ 90,716	55	73,921	\$ 11,865,864	\$ -	\$ 1,090,663	\$ 22,978	\$ 215,743
2019	335	229,159	\$ 27,350,688	\$ -	\$ 1,661,160	\$ -	\$ 81,644	37	37,318	\$ 5,385,942	\$ -	\$ 888,614	\$ -	\$ 145,566
2020	297	100,691	\$ 8,837,242	\$ -	\$ 789,445	\$ -	\$ 29,755	50	85,439	\$ 16,812,859	\$ -	\$ 4,054,020	\$ 31,526	\$ 336,257